



Boil Water Notice for Community Public Water Systems

Affected areas is as follows: FM 2520 to FM 1421, (east to west)
and Exp 77 to Rice Tract Rd (north and south)

January 19, 2024

Due to a major air line break at the Joines Rd WTP, the plant had to be completely bypassed. The Plant is getting all the water from a well in the area and being injected with chlorine at the blend tank. Elevated finished turbidity is 3.1 NTU, and water may appear yellow. the Texas Commission on Environmental Quality has required the Military Highway Water Supply Corporation, PWS ID 1080067, public water system to notify all customers to boil their water prior to consumption (e.g., washing hands/face, brushing teeth, drinking, etc). Children, seniors, and persons with weakened immune systems are particularly vulnerable to harmful bacteria, and all customers should follow these directions).

To ensure destruction of all harmful bacteria and other microbes, water for drinking, cooking, and ice making should be boiled and cooled prior to use for drinking water or human consumption purposes. The water should be brought to a vigorous rolling boil and then boiled for two minutes.

In lieu of boiling, individuals may purchase bottled water or obtain water from some other suitable source for drinking water or human consumption purposes.

When it is no longer necessary to boil the water, the public water system officials will notify customers that the water is safe for drinking water or human consumption purposes.

Once the boil water notice is no longer in effect, the public water system will issue a notice to customers that rescinds the boil water notice in a manner similar to this notice.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions concerning this matter, you may contact our Customer Service Department at 956-565-2491 or General Manager, Mrs. Consuelo De La Rosa at 956-565-2492.

“This institution is an equal opportunity provider and employer.”

Military Highway Water Supply Corporation
P.O. Box 250 • Progreso, Texas 78579
Phone (956) 565-2491 • Fax (956) 565-9471